

Government Of Bihar
Public Health Engineering Department, Nawada
WATER QUALITY REPORT

District Name : NAWADA				Sample Collected on 24.06.2023 by Bhushan Kumar & Received in the Laboratory on 24.06.2023																		
Sl. No.	Block	Panchayat	Village	Nearest Person	Location Of Source	Latitude	Longitude	June, 2023														
1	2	3	4	5	6	7	8	pH	Turb.	EC	TDS	TH	Ca	Mg	Cl	Alka	Fe	NO ₃	SO ₄	F	As	T.coli
1	Akabarapur	Makhar	Makhar	Bless International School, NH-31, Chisti Nager, Makhar, Nawada (Bihar)	01, Sample Direct Boring			7.54	-	492	320	280	72	24.00	55	180	0.1	12.5	24	0.68	-	(-) Ve
Desirable Limit* (PPm)								6.5-8.5	1.0	-	500	200	75	30	250	200	1.0	45	150	1.0	0.01	0.0
Permissible Limit* in absence of alternate source (PPm)								NR	5.0	-	2000	600	200	100	1000	600	NR	NR	400	1.5	0.05	<1.1

Sgt. H. K. Singh
 26.06.2023
 Lab Assistant
 P.H. Division, Nawada

Bhushan Kumar
 26.06.2023
 Chemist
 P.H. Division, Nawada

Ashwini Kumar
 26.06.2023
 for Executive Engineer
 P.H. Division, Nawada